

# Certificate of Compliance

*Awarded to:*

**Lubrizol LifeSciences**

# **Lubrizol**

TSS certifies that:

CLEANROOM, located at Lubrizol LifeSciences 547 TRM Circle, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-7) for particles  $\geq 0.5 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$  under At Rest/Static conditions.

**Refer to TSS Project Report LA-VST22605G-1 for supporting data.**

*Presented by:*



620 Hearst Avenue, Berkeley, CA 94710  
(800) 877-7742 - [www.techsafety.com](http://www.techsafety.com)

**Effective Date: 01/07/2023**

**Expiration Date: 01/07/2024**

**Approved By:** Lauren Stanton  
Technical Writing Manager  
Technical Safety Services (TSS)

# Certificate of Compliance

*Awarded to:*

**Lubrizol LifeSciences**

# **Lubrizol**

TSS certifies that:

FUTURE GOWN RM, located at Lubrizol LifeSciences 547 TRM Circle, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles  $\geq 0.5 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$  under At Rest/Static conditions.

**Refer to TSS Project Report LA-VST22605G-1 for supporting data.**

*Presented by:*



620 Hearst Avenue, Berkeley, CA 94710  
(800) 877-7742 - [www.techsafety.com](http://www.techsafety.com)

**Effective Date: 01/08/2023**

**Expiration Date: 01/08/2024**

**Approved By:** Lauren Stanton  
Technical Writing Manager  
Technical Safety Services (TSS)

# Certificate of Compliance

*Awarded to:*

**Lubrizol LifeSciences**

# **Lubrizol**

TSS certifies that:

GOWN ROOM, located at Lubrizol LifeSciences 547 TRM Circle, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles  $\geq 0.5 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$  under At Rest/Static conditions.

**Refer to TSS Project Report LA-VST22605G-1 for supporting data.**

*Presented by:*



620 Hearst Avenue, Berkeley, CA 94710  
(800) 877-7742 - [www.techsafety.com](http://www.techsafety.com)

**Effective Date: 01/07/2023**

**Expiration Date: 01/07/2024**

**Approved By:** Lauren Stanton  
Technical Writing Manager  
Technical Safety Services (TSS)

# Certificate of Compliance

*Awarded to:*

**Lubrizol LifeSciences**

# **Lubrizol**

TSS certifies that:

VESTIBULE, located at Lubrizol LifeSciences 547 TRM Circle, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles  $\geq 0.5 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$  under At Rest/Static conditions.

**Refer to TSS Project Report LA-VST22605G-1 for supporting data.**

*Presented by:*



620 Hearst Avenue, Berkeley, CA 94710  
(800) 877-7742 - [www.techsafety.com](http://www.techsafety.com)

**Effective Date: 01/08/2023**

**Expiration Date: 01/08/2024**

**Approved By:** Lauren Stanton  
Technical Writing Manager  
Technical Safety Services (TSS)